

Request for Proposal

For

Design, engineering, supply, Installation, testing, and Commissioning of 11KV Overhead lines, CSS, outdoor LT Boards, DG Sets, & high masts with civil constructions on turnkey basis and 8 year Comprehensive O&M at GMDC Baitarani-west Mine, Odisha

RFP No. GMDC/BW/02/2025-26

Answer to Pre- Bid Queries and Corrigendum Document - 3

Gujarat Mineral Development Corporation Ltd.

May 2026

Response to Pre-Bid Queries

Sl. No.	Name of the Bidder	Clause No.	Pre-Bid queries/ Clarification required	Response / Addendum / Corrigendum if any
1.	Babamani Electricals Pvt. Ltd.	Sl. No. 6 Turnkey responsibilities Page No. 19	In view of the point, we came to know that the actual ascertained work not mentioned clearly for which we can not estimated exact value for price quote. And order required additionally for the other ascertained work beyond our scope of work. Kindly clarify that.	The scope of work defined in the RFP is on a turnkey basis and includes all activities required to make the project fully operational. The RFP specified major components of the system. The Bidders are required to undertake their own due diligence, including site visit and detailed review of the RFP, site assessment, and evaluation of all associated works necessary for complete execution of the project. The bidders shall be deemed to have included all such works, whether explicitly mentioned or not but required for successful commissioning and operation of the project, in their price bid.
2.	Babamani Electricals Pvt. Ltd.	Sl. No. 7 Statutory & Obligatory Approvals Page No. 19	In the RFP, wherever we can not explained the exact place of where the metering unit, DP structure, length of 11kv line of DISCOM, the contract demand not mentioned clearly. In other hand the DISCOM line demand note fee, Govt. statutory deposit, liasioning cost paid by consignee@GMDC. We will provide only manpower, T&P and aforesaid materials for execution. Kindly clarify that.	<ul style="list-style-type: none"> • The scope includes construction of 11 kv transmission line from main downcomer DP totaling 5KM. • Coordination and liasioning for obtaining statutory approvals are in the scope of the Agency but statutory fees shall be paid by GMDC directly to relevant Authorities. GMDC shall also provide all documentation related support.
3.	Babamani Electricals Pvt. Ltd.	Sl. No. 7 Statutory & Obligatory	In the RFP, as the tender consists in electrical works, so the Approvals from Odisha Pollution Control Board (OPCB) for	As the project scope encompasses DG sets, the procurement of statutory approvals and 'Consent to Establish' and 'Consent to Operate' from the

Sl. No.	Name of the Bidder	Clause No.	Pre-Bid queries/ Clarification required	Response / Addendum / Corrigendum if any
		Approvals Page No. 19	Consent to Establish (CTE) and Consent to Operate (CTO) is not required. Kindly clarify that.	Odisha Pollution Control Board (OSPCB) is essential and shall be the responsibility of the Agency. All statutory fees shall be paid by GMDC directly to the respective statutory authorities.
4.	Babamani Electricals Pvt. Ltd.	5.1 Qualification Criteria sl. no. (7) Page No. 45	Kindly clarify to the point- 'Similar Nature of Work'. The subject cited tender is serving by 11KV voltage or below voltage. Hence the completion certificate / work orders/ performance certificate can be considered as 1.1KV/3.3KV voltage level or not below the 1.1KV/3.3KV voltage during last seven years.	Please refer to answer to Pre Bid query No .8
5.	Babamani Electricals Pvt. Ltd.	Sl. No. D. (a) Project Scope Boundaries Page No. 25	In the RFP, wherever we can not explained the exact place the where the metering unit, DP structure, length of 11kv line to be constructed of DISCOM. Kindly clarify that	<p>The scope includes construction of 11 kv transmission line from main downcomer DP totaling 5KM. Please note the maximum length is fixed in order to arrive at costing.</p> <p>Since it is a turnkey contract, the Bidders shall be required to undertake their own detailed due diligence, including site visits, assessment of site conditions, coordination requirements with the concerned DISCOM, and evaluation of all necessary infrastructure elements required for project execution.</p> <p>The bidder shall be deemed to have accounted for all such aspects, including the location of metering points, DP structures, and the length of 11 kV line, while preparing and submitting their bid.</p>
6.	Babamani Electricals Pvt. Ltd.	SECTION-V PRICES AND PAYMENT TERMS	In the RFP, CAMC is not possible to execute till 8 years after completion of 2-years warranty period for which consumable	RFP Condition remain unchanged

Sl. No.	Name of the Bidder	Clause No.	Pre-Bid queries/ Clarification required	Response / Addendum / Corrigendum if any
		SL.NO. 3 SUB SL. NO. 3.1 PAGE NO. 62	materials in CAMC can not be estimated exactly to quote the prices for CAMC. Therefore, it may decrease the CAMC period from 8 years to 3-4 years. Even if the CAMC for 8 years taken into the account, the consumable materials will provide by the Consignee@GMDC to execute the CAMC and we will fix the materials with manpower, T&P while CAMC required.	
7.	Bhavin Enterprise Pvt. Ltd.	Clause 5.1 Qualification Criteria	Since civil work is also required in this project on your part, a civil contractor is also needed, for which a joint venture is necessary. We humbly request you to arrange this.	The proportion of civil and structure work (Cable trenches , Civil works for switchyard area, earth work etc.) is relatively smaller. Therefore, JV is not needed. However, the Turnover requirements stands amended as below. <i>“Bidder shall have an average audited annual turnover of ₹2.14 crore in any three (3) continuous years out of the last five (5) financial years (FY 2019–20 to FY 2024–25). The Bidder should submit the Certificate(s) from statutory auditor with all relevant details from the bidder. The bidder shall provide a copy of any 3 of the annual audited report to ascertain its turnover.”</i>
8.	Bhavin Enterprise Pvt. Ltd.	Clause 5.1 Qualification Criteria	The experience requested by you, which has been taken according to the total tender amount, should actually consider only the maintenance amount, because it starts only after the installation work is completed, and that too is billed monthly, which should not be counted in this. Therefore, I humbly	The clause 5.1 (7) stands revised as below. <i>“The Bidder should have successfully completed or substantially completed Similar Nature of Works during last seven years 01/01/2019 to 01/01/2026 should be either of the following: -</i>

Sl. No.	Name of the Bidder	Clause No.	Pre-Bid queries/ Clarification required	Response / Addendum / Corrigendum if any
			request that experience be requested based on 60% of its original amount.	<p>Three similar completed works each costing not less than the amount equal to Rs 2.86 crore or;</p> <p>Two similar completed works each costing not less than the amount equal to Rs 3.57 crore or;</p> <p>One similar completed work costing not less than the amount equal to Rs 5.7 crore</p> <p>“Similar Nature of Work” is defined as below. “Supply, installation, testing and commissioning of minimum of 11 KV/33KV overhead and underground electrical network with relevant accessories or 33/11KV Substations in government/semi government/private sector/PSUs.”</p>
9.	Bhavin Enterprise Pvt. Ltd.	Clause 1.6 Schedule of Bidding	The deadline for submitting the tender needs to be extended because, due to the end of March, we are unable to give attention to this tender, and we also humbly request that the pre-bid meeting be rescheduled accordingly if possible.	The Bid submission date extended. Please refer to Annexure for the extension
10.	Bhavin Enterprise Pvt. Ltd.		In the mine plan, it is necessary to upload a plan indicating your requirements such as mining, web bridge, office, time office, and dumping site locations so that we can finalize the item-wise quantity.	The details pertaining to the mine plan shall be shared with the onboarded Agency post signing of a Non-Disclosure Agreement.
11.	Bhavin Enterprise Pvt. Ltd.		<p>Add make to the item's make list, such as.</p> <ol style="list-style-type: none"> 1. VCB - SCHNEIDER ,CROMPTON 2. CSS - SCHNEIDER ,C & S 3. DG SET – SUPERNOVA 	<p>Please refer to the make lists provided below</p> <ol style="list-style-type: none"> 1. Main outdoor 11 KV VCB Station (01 Nos.) : Siemens, GE , L&T, Schneider, Crompton

Sl. No.	Name of the Bidder	Clause No.	Pre-Bid queries/ Clarification required	Response / Addendum / Corrigendum if any
			4. HIGHMAST TOWER - RR ISPAT.VOLMOUNT.TRANSRAIL	2. Area Compactible Substations (CSS) (total-05Nos.): Siemens, GE , L&T, Schneider, Crompton 3. 250KVA and 120KVA DG Sets with emergency Supply Boards (01 nos. each): Crompton, Cummins , Kirloskar 4. High mast lighting Tower (total-06Nos.): Bajaj, RR Ispat, Volmount , Sigma
12.	Bhavin Enterprise Pvt. Ltd.		At the close of turnover, 25% of the work completion amount is to be kept in such a way that it can be within any 1 year over a period of seven years. This is our humble request.	Please refer to answer to Pre Bid Query no 7 for the amended Turnover requirement.
13.	Bhavin Enterprise Pvt. Ltd.		There is no clarity on providing the vehicle during the GMDC maintenance period, it is requested to provide it.	GMDC shall provide vehicle for the internal transport needs for the Agency's personnel along with GMDC's officials during the Warranty and O&M period
14.	Bhavin Enterprise Pvt. Ltd.		During the tender work as well as during maintenance, it is requested to provide clarification for placing materials on the site and providing space for workers to sit.	GMDC shall provide the one space for storage of material at Site
15.	ELEMECH ENGINEERS	Clause 5.1 Qualification Criteria	Civil Work & Joint Venture Requirement: As the scope of work includes civil construction, the involvement of a civil contractor is essential. Therefore, we kindly request you to permit or facilitate a Joint Venture (JV) arrangement to meet this requirement effectively.	Please refer to answer to Pre bid query no 7
16.	ELEMECH ENGINEERS	Clause 5.1 Qualification Criteria	Experience Criteria: The experience criteria currently appear to be based on the total tender value. However, we request that the experience requirement be considered only for the execution portion, excluding the Operation & Maintenance (O&M) component. Since O&M commences after project	Please refer to answer to Pre bid query no 8

Sl. No.	Name of the Bidder	Clause No.	Pre-Bid queries/ Clarification required	Response / Addendum / Corrigendum if any
			<p>completion and is billed monthly, it should not be included in the experience calculation.</p> <p>Hence, we humbly request that the experience requirement be revised to 60% of the original execution value</p>	
17.	ELEMECH ENGINEERS	Clause 1.6 Schedule of Bidding	Extension of Submission Deadline: Due to the financial year closing activities at the end of March, we are unable to devote adequate attention to this tender. Therefore, we request an extension of the tender submission deadline. Additionally, we also request rescheduling of the pre-bid meeting accordingly, if possible.	The Bid submission date extended. Please refer to Annexure of this document for the details.
18.	Diversified Energy Solutions Pvt Ltd (DESPL)	Clause Number 5.7, Page Number 45 One similar completed work costing not less than the amount equal to Rs 11.2 crore	<p>Reduction of Threshold value to Rs 5.0 Cr : One similar completed work costing not less than the amount equal to Rs 5.0 Crore and One Township (Of any Coal Mining Organisation) Maintenance work of value Rs 6.0 Crore</p> <p>Rationale</p> <p>Keeping in view the requirement the average Annual Turnover of Rs 4.2 Cr ,our humble submission for reduction of thresh hold value for One Similar Work. We are having HT Electrical License issued by ELBO and achieved turn over of Rs 151 Cr in FY 24-25 and well placed to execute the current project under consideration.</p>	Please refer to answer to Pre bid query no 8
19.	Diversified Energy Solutions Pvt Ltd (DESPL)	Clause Number 5.8 ,Page Number 45 The Bidder should have executed	<p>O&M Works of Township of any Coal Mining Organization for at least one year</p> <p>The Bidder should have executed O&M works related to 11KV Network or 33KV Network or 33/11KV Substations Operations in any Distribution utility Or Electrical O&M</p>	<p>The Clause stands amended as below.</p> <p>“The Bidder should have executed O&M works related to 11KV Network or 33KV Network or 33/11KV Substations Operations in any Distribution utility or Electrical O&M Works related</p>

Sl. No.	Name of the Bidder	Clause No.	Pre-Bid queries/ Clarification required	Response / Addendum / Corrigendum if any
		O&M works related to 11KV Network or 33KV Network or 33/11KV Substations Operations in any Distribution utility for at least one year in last seven years. The Bidder must submit the Copy of work order / completion certificate to be submitted in this regard.	Works related to 11KV Network or 33KV Network or 33/11KV Substations Operations of Township of any Coal Mining Organization for at least one year in last seven years. The Bidder must submit the Copy of work order / completion certificate to be submitted in this regard. Rationale: O & M Works related to 11KV Network or 33KV Network or 33/11KV Substations Operations meant for Distribution Utility Or For any Townships are same in terms of nature of work and functionalities as the common objective is smooth and Interruption Free Power Supply Distribution..	to 11KV Network or 33KV Network or 33/11KV Substations Operations in any Township for at least one year in last seven years. The Bidder must submit the Copy of work order / completion certificate to be submitted in this regard.”
20.	Diversified Energy Solutions Pvt Ltd (DESPL)	Design and Engineering Documents	We understand that the Design and Engineering Document comprising of SLD, BOM, Equipment Specification and make would be part of Technical Bid Submission. Kindly Clarify.	The Bidder should submit preliminary SLD comprising of BOM, Equipment Specification and make as part of Technical Proposal. The Agency shall have to submit detailed Design and Engineering documents as per Section II A (1) of the RFP.
21.	Diversified Energy Solutions Pvt Ltd (DESPL)	Site Visit	We comprehend that, Site Visit Certificate issued by Engineer Incharge at Site also is to be part of Technical Bid Submission. Kindly Clarify.	Yes, Site Visit stands added as mandatory requirements/ qualification criteria for the due diligence. The Bidder shall have to submit the certificate to evidence the site visit. Following Stand added as clause 5.1 (12)

Sl. No.	Name of the Bidder	Clause No.	Pre-Bid queries/ Clarification required	Response / Addendum / Corrigendum if any
				"The Bidder shall have to submit the certificate to evidence the site visit"
22.	Diversified Energy Solutions Pvt Ltd (DESPL)	General	<p>We comprehend that the Design and Engineering documents would be part of technical bid submission. We have visited the site and were under impression that the Design & Engineering Document would be submitted as post award of contract.</p> <p>Now, having understood the timing of submission of Design & Engineering Document, it would be of paramount importance on our part to make the site visit once again with the prospect of building the Design & Engineering Document. To prepare a quality Design & Engineering Document comprising of SLD (Single Line Diagrams), BOM, Technical specification and Make Details ,we would be requiring additional time.</p> <p>Keeping this in view, we humbly request your goodself to extend the Due date of Submission by two weeks the effective form 11th May 2026 for which the undersigned would highly grateful to you.</p>	The Bid submission date is extended. Please refer to Annexure of this document for the extension

Annexure-1 : Schedule of Bidding stand amended

Clause 1.6. Schedule of Bidding stands amended as below.

Sl. No.	Event Description	Clause as per the Corrigendum 2	Addendum / Corrigendum if any
5	Online Submission of Price Bid	The Price Bid is to be submitted online only at the designated place on https://gmdc.nprocure.com 11/05/2026 up to 18:00 hrs. and (i) any submission of offline price bid (i.e., physical submission) or (ii) submission of price bid along with technical bid will lead to disqualification. Technical Bid is not to be submitted online but should be submitted in physical offline mode after the submission of the Price Bid at the designated address by the deadline mentioned.	The Price Bid is to be submitted online only at the designated place on https://gmdc.nprocure.com 26/05/2026 up to 18:00 hrs. and (i) any submission of offline price bid (i.e., physical submission) or (ii) submission of price bid along with technical bid will lead to disqualification. Technical Bid is not to be submitted online but should be submitted in physical offline mode after the submission of the Price Bid at the designated address by the deadline mentioned.
6	Last Date and Time of Submission of Technical Bid, RFP Fees & EMD in Hard Copy	The Technical Bid is to be submitted offline, on or before 15/05/2026 up to 18:00 Hrs. at GMDC office situated at Khanij Bhavan, 132-ft. Ring Road, Gujarat University Ground, Vastrapur, Ahmedabad- 380052, by Speed Post/RPAD/Hand delivery/Courier in sealed cover duly super scribed as mentioned in the RFP.	The Technical Bid is to be submitted offline, on or before 30/05/2026 up to 18:00 Hrs. at GMDC office situated at Khanij Bhavan, 132-ft. Ring Road, Gujarat University Ground, Vastrapur, Ahmedabad- 380052, by Speed Post/RPAD/Hand delivery/Courier in sealed cover duly super scribed as mentioned in the RFP.
7	Opening of Technical Bid	On 18/05/2026 AT 12:00 Hrs. at GMDC office	On 02/06/2026 AT 12:00 Hrs. at GMDC office